

Mason, Samantha

From: Ryan, Matt on behalf of Flood Risk Management
Sent: 05 August 2021 16:15
To: Contact, Planning
Subject: RE: Planning Application Consultation 21/77995/HH

Categories: neigh cons to be done as urgent

Dear Planning,

I have no objection to this application. The site is entirely within flood zone 1 and will cause no increase to flood risk.

All drainage works must be undertaken in accordance with Building Regulations Approved Document H.

Kind regards,

Matt Ryan
Senior Engineer (Flood Risk & Drainage)
Place | Salford City Council
Salford Civic Centre | Chorley Road | Swinton | M27 5FJ

Tel: 07929 826 936
Email: matt.ryan@salford.gov.uk

-----Original Message-----

From: planning.contact@salford.gov.uk <planning.contact@salford.gov.uk>
Sent: 21 July 2021 09:16
To: Flood Risk Management <FloodRisk@salford.gov.uk>
Subject: Planning Application Consultation 21/77995/HH

Please see attached planning application consultation document